

**Request for Proposals**

**Dolly McNutt Plaza  
Paducah, KY**

**Date of Issue: July 7, 2025**

Re: Request for Proposals  
Dolly McNutt Plaza  
City of Paducah  
300 S. 5<sup>th</sup> Street  
Paducah, KY 42003

**Addendum No. 3**

This document is an amendment to the original Request for Proposals and shall be a part of and included in the final contract award. Wherein this Addendum conflicts with the original Request for Proposals, this Addendum shall govern.

RFP – Dolly McNutt Lighting Project

**Item No. 1. Scope of Work (page 4)**

Question: Do lights have to be 100% solar? Please provide more clarification.

Answer: No. Solar or Photocell will be considered. However, considering the shade in the project area hardwiring new fixtures using existing wiring if possible, is preferred.

**End of Addendum No. 3**